

COVER PAGE

SM03502



ANALYSIS FOR:			ADDITIONAL COPY TO:		
Bill Wolfe Norlite 628 S. Saratoga St. Cohoes NY 12047					
LAB ID	SAMPLE ID	SAMPLE TYPE	DATE SAMPLED	DATE RECEIVED	DATE COMPLETED
SM03502	Norlite 3/4x No. 4		6/11/2010	6/15/2010	6/24/2010

Green Roof Media Analysis

Results on dry weight basis unless specified otherwise

Analysis	Units	Result	FLL Guidelines for Single Course Extensive Sites ¹
Particle Size Distribution (See accompanying report)			
≤ 0.05 mm (Fill reference value based on < 0.06 mm)	mass %	0.9	≤ 10
Denisty Measurements			
Bulk Density (dry weight basis)	g/cm ³	0.82	—
Bulk Density (dry weight basis)	lb/ft ³	51.18	—
Bulk Density (at max. water-holding capacity)	g/cm ³	0.91	—
Bulk Density (at max. water-holding capacity)	lb/ft ³	56.82	—
Water/Air Measurements			
Moisture	mass %	8.6	—
Total Pore Volume ²	Vol. %	56.6	—
Maximum water-holding Capacity	Vol. %	11.6	20 - 65
Air-Filled Porosity (at max water-holding capacity)	Vol. %	44.9	≥ 10
Water permeability (saturated hydraulic conductivity)	cm/s	> 0.738	0.1 - 0.67
Water permeability (saturated hydraulic conductivity)	in/min	> 17.431	2.36 - 15.8
pH and Salt Content			
pH (CaCl ₂)		8.9	6.0 - 8.5
Soluble salts (water, 1:10, m:v)	mmhos/cm	0.09	—
Soluble salts (water, 1:10, m:v)	g (KCl)/L	0.45	≤ 3.5
Organic Measurements			
Organic matter content	mass %	0.0	—
Organic matter content	g/L	0.0	≤ 40

GR02: Single Course Extensive

¹Forschungsgesellschaft Landschaftsentwicklung Landschaftsbau (FLL). 2008. Guidelines for the Planning Execution and Upkeep of Green-Roof Sites

²Total pore volume determined using measured particle density instead of assumed particle density as specified in FLL



ANALYSIS FOR:			ADDITIONAL COPY TO:		
Bill Wolfe Norlite 628 S. Saratoga St. Cohoes NY 12047					
LAB ID	SAMPLE ID	SAMPLE TYPE	DATE SAMPLED	DATE RECEIVED	DATE COMPLETED
SM03502	Norlite 3/4x No. 4		6/11/2010	6/15/2010	6/24/2010


Green Roof Media Particle Size Distribution

Particle Size Analysis		Sum of particles less than size specified			
Diameter -mm-	%	Diameter -mm-	Diameter -in-	Sieve size	% sum of particles
< 0.002	0.4	< 0.002	---	---	0.4
0.002-0.05	0.5	< 0.05	---	---	0.9
0.05-0.25	0.5	< 0.25	0.0098	60 mesh	1.4
0.25-1.0	0.3	< 1.0	0.0394	18 mesh	1.7
1.0-2.0	0.1	< 2.0	0.0787	10 mesh	1.8
2.0-3.2	0.2	< 3.2	0.125	1/8 inch	1.9
3.2-6.3	2.5	< 6.3	0.250	1/4 inch	4.5
6.3-9.5	22.1	< 9.5	0.375	3/8 inch	26.6
9.5-12.5	49.6	< 12.5	0.500	1/2 inch	76.2
> 12.5	23.8				



ANALYSIS FOR:			ADDITIONAL COPY TO:		
Bill Wolfe Norlite 628 S. Saratoga St. Cohoes NY 12047					
LAB ID	SAMPLE ID	SAMPLE TYPE	DATE SAMPLED	DATE RECEIVED	DATE COMPLETED
SM03502	Norlite 3/4x No. 4		6/11/2010	6/15/2010	6/24/2010

Green Roof Media FLL¹ Particle Size Distribution Graph for Single Course Extensive Systems



¹Forschungsgesellschaft Landschaftsentwicklung Landschaftsbau (FLL). 2008. Guidelines for the Planning Execution and Upkeep of Green-Roof Sites